

**Lot 10 Emerald Hills Estates**  
**Septic System Options**

1. Site is suitable for a shallow in-ground system sized at .4 gpd/sqft. System elevation should be in 1.0'- 2.0' below original grade. Dose tank may be required. Drop boxes or distribution box recommended. System to be installed when the ground is dry to prevent smearing of the sidewalls.
2. Site is also suitable for an at-grade system or 6" mound system

Any questions on your septic system option please call the above number.