

in accordance with Comm 85, Wis. Adm. Code

Attach complete site plan on paper not less than 8 1/2 x 11 inches in size. Plan must include, but not limited to: vertical and horizontal reference point (BM), direction and Percent slope, scale or dimensions, north arrow, and location and distance to nearest road.

Please print all information.

Personal information you provide may be used for secondary purposes (Privacy Law, s. 15.04 (1) (m)).

County: Washington County	
Parcel I.D.:	
Reviewed by:	Date:

Property Owner: Plow and Hearth LLC				Property Location: Govt. Lot <input checked="" type="checkbox"/> 1/4 1/4 S 30 T 9 N - R 18 E (or) W <input type="checkbox"/>			
Property Owner's Mailing Address:				Lot # 12	Block #	Subd. Name or CSM # Emerald Hills Estates	
City:	State:	Zip Code:	Phone Number: () -	<input type="checkbox"/> City: <input type="checkbox"/> Village: <input checked="" type="checkbox"/> Town:		Nearest Road:	

<input checked="" type="checkbox"/> New Construction	Use <input checked="" type="checkbox"/> Residential / Number of bedrooms: 4	Code derived design flow rate: 600 GPD
<input type="checkbox"/> Replacement	<input type="checkbox"/> Public or commercial - Describe:	
Parent material: Glacial till and outwash		Flood Plain elevation if applicable: N/A ft.
General comments and recommendations: SEE MEMO SHEET		

1 Boring # Boring Pit Ground surface elev. 982.2 ft. Depth to limiting factor >80 in. Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
									Eff#1	Eff#2
Ap	0-7	10 YR 4/2		SiL	2f-m gr	mvfr	as	3f-2m	.6	.8
Bt	7-11	10 YR 5/4		SiCL	2 f sbk	mfi	cs	2f-1m	.4	.6
Bt2	11-36	10 YR 4/4		CL	2 m abk	mfi	cs	1f	.4	.6
2BC	36-48	10 YR 5-4/4		gr SL	1 f asbk	mfr	as	--	.4	.7
2C	48-80	10 YR 5/3		gr L	0m	mfr	--	--	.2	.5

2 Boring # Boring Pit Ground surface elev. 990.5 ft. Depth to limiting factor >84 in. Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
									Eff#1	Eff#2
Ap	0-9	10 YR 4/2		SiL	2f-m gr	mvfr	as	2f-1m	.6	.8
Bt	9-13	10 YR 5/4		SiCL	2 f-m abk	mfi	cs	1f-1m	.4	.6
2Bt	13-26	10 YR 4/4		CL	2 f abk	mfr-ml	cs	1f	.4	.6
2BC	26-36	10 YR 5-4/4		gr SL	1 f abk	ml	--	--	.4	.7
2C	36-84	10 YR 5/4-3		gr SL	0m	mfr	--	--	.2	.6

* Effluent # 1 = BOD₅>30 ≤ 220 mg/L and TSS > 30 ≤ 150 mg/L

* Effluent # 2 = BOD₅≤ 30 mg/L and TSS ≤ 30 mg/L

CST Name (Please Print): David B. LaBott(Baudhuin Inc.)	Signature:	CST Number: 71449
Address: 55 South Third Ave. Sturgeon Bay, WI 54235	Date Evaluation Conducted: 4-28-04	Telephone Number: (920) 743 - 8211

3

Boring #

Boring

Pit Ground surface elev. 977.1 ft. Depth to limiting factor 52 in.

Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
									Eff#1	Eff#2
Ap	0-12	10 YR 3/2		SiL	2 f-m gr	mvfr	as	3f-2m	.6	.8
Ab	12-18	10 YR 4/2		SiL	2 f-m abk	mfi	cs	2f-1m	.6	.8
BE	18-22	10 YR 5/2		SiL	2 m abk	mfi	cs	1f	.6	.8
Bt1	22-52	10 YR 5/4		SiCL	2 f-m abk	mfi	cs	--	.4	.6
Bt2	52-80	10 YR 5/4-3	f1f 10 YR 5/8	SiCL	1 f abk	mfi	--	--	.2	.3

4

Boring #

Boring

Pit Ground surface elev. 982.2 ft. Depth to limiting factor >81 in.

Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
									Eff#1	Eff#2
Ap	0-9	10 YR 4/2		SiL	2f-m abk	mfr	as	2f-1m	.6	.8
Bt	9-20	7.5 yr 4/4		CL	2 f-m abk	mfi	cs	2f	.4	.6
2Bt	20-26	10 YR 4/4		gr SCL	2 m-co sbk	mfi	cs	--	.4	.6
2BC	26-36	10 YR 5/4		gr SL	1 f sbk	mfr	cw	--	.4	.7
2C	36-81	10 YR 5/3		gr L	0m	mfr	--	--	.2	.5

5

Boring #

Boring

Pit Ground surface elev. 984.5 ft. Depth to limiting factor >81 in.

Soil Application Rate

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	GPD/ft ²	
									Eff#1	Eff#2
Ap	0-9	10 YR 4/2		SiL	2f-m abk	mfr	as	2f-1m	.6	.8
Bt	9-17	10 YR 4/4		CL	2 f-m abk	mfr	cs	2f	.4	.6
2BC	17-36	10 YR 4/4		gr SL	2 f sbk	mfr	cs	--	.6	1.0
2C	36-81	10 YR 5/4-3		gr SL	1 f abk	mfr	--	--	.4	.7

* Effluent # 1 = BOD₅>30 ≤ 220 mg/L and TSS > 30 ≤ 150 mg/L

* Effluent # 2 = BOD₅≤ 30 mg/L and TSS ≤ 30 mg/L

The Department of Commerce is an equal opportunity service provider and employer. If you need assistance to access services or need material in an alternate format, please contact the department at 608-266-3151 or TTY 608-264-8777.

